

CITY OF DEXTER, MISSOURI

INVITATION FOR BIDS

DEXTER MUNICIPAL AIRPORT GENERATOR PROJECT

The City of Dexter is accepting sealed bids for the purchase, delivery, installation, startup, and testing of a diesel-powered standby generator, capable of producing a minimum of 100 kW of power, at the Dexter Municipal Airport, located at 911 Harry Bennett Drive, Dexter, Missouri.

The generator shall include a fuel tank capable of providing approximately a minimum of 48 hours of continuous operation. Installation will be on a concrete pad provided by others.

**SEE ADDENDUM NO. 1**

Bids shall include:

- Manufacturer and model information
- Generator specifications and technical data sheets
- Warranty information
- Delivery and installation timeline
- Total project cost, including equipment, freight, installation, startup, and testing
- References for similar projects

Sealed bids must be clearly marked:

DEXTER MUNICIPAL AIRPORT GENERATOR PROJECT

Bids should be mailed or hand-delivered to:

City of Dexter  
Attn: Airport Generator Bid c/o Lauren Hill  
301 East Stoddard Street  
Dexter, MO 63841

Bids must be received no later than 10:00 a.m. on Friday, July 10, 2026. Bids will be publicly opened at 10:00 a.m. on Friday, July 10, 2026, at Dexter City Hall, 301 East Stoddard Street, Dexter, Missouri 63841.

Questions may be directed to Lauren Hill at (573) 624-5959.

The City of Dexter reserves the right to reject any or all bids and to accept the bid determined to be in the best interest of the City.

The City of Dexter is an Equal Opportunity Employer and encourages participation by minority-owned and women-owned businesses.

**ADDENDUM NO. 1**

The Invitation for Bids for the Dexter Municipal Airport Generator Project is amended as follows:

1. The generator system shall include two (2) Automatic Transfer Switches (ATS) compatible with the proposed generator and properly sized for the intended application.
2. Electrical wiring and all related electrical work will be completed under a separate contract and shall not be included in this bid.
3. The concrete pad/foundation will be provided by others and shall not be included in this bid.
4. Bidders shall include all costs associated with furnishing, delivery, startup, testing, and commissioning of the generator and two (2) Automatic Transfer Switches.

All other terms, conditions, specifications, and requirements of the original Invitation for Bids remain unchanged and in full force and effect. Bidders shall acknowledge receipt of this Addendum with their bid submission.